Weidmüller ϽΞ

CABTITE SE 5-6 SML GY

Similar to illustration

Whether a large or small cable diameter – Cabtite always offers the right seal insert.

The conical shape of the sealing elements allows the previously positioned snap-in grid inlays to be pushed in easily from the inside to the outsid. It reliably seals intermediate spaces and provides strain relief in accordance with DIN EN 62444. The seal inserts combined with the frames achieve an IP 66 degree of protection. As a result of its slotted design with wave cut, it is especially suitable for pre-assembled cables.

- The black seal inserts are designed for a particularly high operating temperature and offer fire safety class UL 94 HB
- The grey sealing elements comply with fire safety class UL 94 V0 and are therefore suitable for the demands of the railway industry
- By using multiple inserts, two or more cables, as well as special cables, can be passed through a sealing element

General ordering data

Version	Sealing element, Cabtite (cable entry system), TPE, Light Grey, Height: 20.3 mm, Width: 20.3 mm, Depth: 17.7 mm, -40 °C...90 °C, IP54, IP65, IP66
Order No.	2583450000
Type	CABTITE SE 5-6 SML GY
GTIN (EAN)	4050118616538
Qty.	10 pc(s).

Creation date February 25, 2021 3:54:38 PM CET

Weidmüller ⟩Ξ

CABTITE SE 5-6 SML GY

Technical data

Dimensions and weights

Depth	17.7 mm		Depth (inches)	0.697 inch
Height	20.3 mm		Height (inches)	0.799 inch
Net weight	6.6 g		Width	20.3 mm
Width (inches)	0.799 inch			

General information

Halogen	No		Material	TPE
Outer cable diameter, max.	6 mm		Outer cable diameter, min.	5 mm
Sealing element	1 small sealing element		Silicone	No
UL 94 flammability rating	V-0			

Classifications

ETIM 6.0	EC000879		ETIM 7.0	EC000879
ECLASS 9.0	27-14-44-21		ECLASS 9.1	27-14-44-21
ECLASS 10.0	27-14-44-21		ECLASS 11.0	27-14-44-21

Approvals

Approvals	c ⟨UL⟩ US
ROHS	Conform
UL File Number Search	E223801

Downloads

Engineering Data	STEP
Engineering Data	EPLAN
User Documentation	Cabtite Installation Instructions

Creation date February 25, 2021 3:54:38 PM CET