

# EC Declaration of Conformity

# PULS

The manufacturer declares hereby, that all power supplies listed below, are in conformity with the provisions of the following European Directives:

**2004/108/EC** Electromagnetic Compatibility Directive  
**2006/95/EC** Low Voltage Directive  
**2011/65/EU** RoHS Directive

Model	Output dc	Output power	Input voltage
<b>ML15.051</b>	5,0 - 5,5V	15W	100-240Vac; 110-300Vdc
<b>ML15.121</b>	12 - 15V	15W	100-240Vac; 110-300Vdc
<b>ML15.241</b>	24 - 28V	15W	100-240Vac; 110-300Vdc
<b>ML30.100</b>	24 - 28V	30W	100-240Vac; 110-300Vdc
<b>ML30.101</b>	5,0 - 5,5V	25W	100-240Vac; 110-300Vdc
<b>ML30.102</b>	10 - 12V	30W	100-240Vac; 110-300Vdc
<b>ML30.106</b>	±12 - 15V	36W	100-240Vac; 110-300Vdc
<b>ML50.100</b>	24 - 28V	50W	100-240Vac; 110-300Vdc
<b>ML50.101</b>	24 - 28V	50W	100-240Vac; 110-300Vdc
<b>ML50.102</b>	12 - 15V	50W	100-240Vac; 110-300Vdc
<b>ML50.105</b>	48 - 56V	50W	100-240Vac; 110-300Vdc
<b>ML50.109</b>	24 - 28V	50W	100-240Vac; 110-300Vdc
<b>ML50.111</b>	24 - 28V	50W	100-240Vac; 110-300Vdc

The following standards were used to assess the products:

**EN 61204-3:2000 Low voltage power supplies, d.c. output, electromagnetic compatibility**

**EN 61000-6-3:2007 +A1:2011 Generic emission standard for residential environments**

- IEC 61000-3-3 / EN 61000-3-3:2008 Limitation of voltage changes, voltage fluctuations and flicker
- EN 55011:2009 +A1:2010 class B and EN 55022:2010 class B radio disturbance

**EN 61000-6-4:2007 +A1:2011 Generic emission standard for industrial environments**

**EN 61000-6-2:2005 Generic immunity standard for industrial environments**

**EN 61000-6-1:2007 Generic immunity standard for residential environments**

**EN 60950-1:2006+A11:2009 +A1:2010 +A12:2011**

**Information technology equipment - Safety – Part 1: General requirements**

PULS GmbH  
Arabellastraße 15  
81925 Muenchen  
Germany

Muenchen, 2013-04-08

*This is the internet version of the EC Declaration of Conformity which bears no signature but is identical to the signed document. If a copy of a declaration with an actual signature should be needed, please contact your local PULS sales office.*

Bernhard Erdl , Managing Director

No. G 322 11 b