

EU Declaration of Conformity

<i>Product:</i>	Residual Current-Operated Circuit Breaker	
-----------------	--	--

<i>Name and address of the manufacturer:</i> Rockwell Automation Inc. 1201 South Second Street Milwaukee, WI 53204 USA	<i>Name and address of the authorised representative:</i> Rockwell Automation B.V. Rivium Promenade 160 2909 LM Capelle aan den IJssel The Netherlands
--	--

This declaration of conformity is issued under the sole responsibility of the manufacturer.

<i>Object of the declaration:</i>	Allen-Bradley 1492-RCDA Series (reference the attached list of catalogue numbers)	
-----------------------------------	---	--

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2006/95/EC & 2014/35/EU	Low Voltage Directive	(LVD)
2004/108/EC & 2014/30/EU	EMC Directive	(EMC)


References to the relevant harmonised standards used or references to the specifications in relation to which conformity is declared:

EN 61008-1:2004 + A11:2007 + A12:2009	Residual current operated circuit-breakers without integral overcurrent protection for household or similar uses (RCCB's) – Part 1: General rules
EN 61008-2-1:1994 + A11:1998	Residual current operated circuit-breakers without integral overcurrent protection for household or similar uses (RCCB's) – Part 2-1: Applicability of the general rules to RCCB's functionality independent of line voltage

Additional information:

<i>Year of CE Marking (LVD):</i>	2014
----------------------------------	------

Signed for and on behalf of the above named manufacturer:

<i>Place and date of issue:</i>	Milwaukee, WI, USA	22-Jan-2016
<i>Name, function:</i>	Daniel L. Nachtigall – Technical Leader, Product Certification Engineering	
<i>Signature:</i>		

<i>Catalogue number</i>	<i>Series ¹</i>	<i>Description</i>
1492-RCDAxxxxx		<i>Residual current-operated circuit breakers per Nomenclature</i>

1) *If no series number is given, then all series are covered*

NOMENCLATURE

1492-RCD	A	4	B	40	S
1	2	3	4	5	6

1	Designates Product Line 1492-RCD – Residual current circuit breakers
2	Designates RCCB Type A – Type A
3	Designates Number of Poles 2 – 2 pole 4 – 4 pole
4	Designates Sensitivity A – 30 mA B – 100 mA C – 300 mA D – 500 mA
5	Designates Current Rating 25 – 25 A 40 – 40 A 63 – 63 A 80 – 80 A
6	Designates Delayed Response Blank – Not provided S – Delayed response option