

EU Declaration of Conformity

| | | |
|-----------------|--|--|
| <i>Product:</i> | Industrial Control Transformers | |
|-----------------|--|--|

| | |
|--|--|
| <i>Name and address of the manufacturer:</i> Rockwell Automation, Inc. 1201 South 2nd Street Milwaukee, WI 53204 U.S.A. | <i>Name and address of the authorised representative:</i> Rockwell Automation B.V. Rivium Promenade 160 2909 LM Capelle aan den IJssel The Netherlands |
|--|--|

This declaration of conformity is issued under the sole responsibility of the manufacturer.

| | | |
|-----------------------------------|--|--|
| <i>Object of the declaration:</i> | Allen Bradley, 1497 Series <i>(reference the attached list of catalogue numbers)</i> | |
|-----------------------------------|--|--|

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

| | | |
|------------------------------------|------------------------------|--------------|
| 2006/95/EC & 2014/35/EU | Low Voltage Directive | (LVD) |
|------------------------------------|------------------------------|--------------|


References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

| | | |
|----------------------------------|--|--|
| EN 61558-1:2005 + A1:2009 | <i>Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests</i> | |
| EN 61558-2-2:2007 | <i>Safety of power transformers, power supplies, reactors and similar products – Part 2-2: Particular requirements and tests for control transformers and power supplies incorporating control transformers</i> | |
| EN 61558-2-6:2009 | <i>Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers</i> | |

Additional information:

| | | |
|----------------------------------|-------------|--|
| <i>Year of CE Marking (LVD):</i> | 2004 | |
|----------------------------------|-------------|--|

Signed for and on behalf of the above named manufacturer:

| | | |
|---------------------------------|---|--------------------|
| <i>Place and date of issue:</i> | Milwaukee, WI USA | 27-Jan-2016 |
| <i>Name, function:</i> | Daniel L. Nachtigall, Technical Leader – Product Certification Engineering | |
| <i>Signature:</i> |  | |

| Catalogue number | Series ¹ | Description | Standards ² | |
|-------------------|---------------------|---|------------------------|--------------|
| | | | EN 61558-2-2 | EN 61558-2-6 |
| 1497-x-xxxx-x-N-x | | Standard control transformers, 63-2000 VA maximum per Nomenclature below | Yes | No |
| 1497-x-Mx-x-N-x | | Multi-tap, control transformers, 63-2000 VA maximum per Nomenclature below | Yes | No |
| 1497-x-xxxx-x-N-x | | Safety isolating transformers, 63-1000 VA maximum per Nomenclature below | No | Yes |
| 1497-x-Mx-x-N-x | | Multi-tap, safety isolating transformers, 63-1000 VA maximum per Nomenclature below | No | Yes |

- 1) If no series number is given, then all series are covered
 2) No = Product is not certified to this standard.
 Yes = Product is certified to this standard.

NOMENCLATURE

Standard Control Transformers

| | | | | | | | | | | |
|------|---|----|---|------|---|----|---|---|---|----|
| 1497 | - | M | - | AADX | - | 0 | - | N | - | M |
| I | | II | | III | | IV | | V | | VI |

| | | |
|------|---|---|
| I. | Product Type 1497 – Industrial control transformer | |
| II. | VA Rating | |
| | A – 63 VA B – 80 VA C – 130 VA D – 200 VA E – 250 VA F – 350 VA | G – 500 VA H – 750 VA J – 800 VA K – 1000 VA L – 1600 VA M – 2000 VA |
| III. | Voltage Rating (First 2 characters = Primary Voltage, Second 2 characters = Secondary Voltages) | |
| | HX – 208 V, 60 Hz AX – 240 V, 60 Hz; 220 V, 50 Hz AA – 240 V, 60 Hz AB – 240/480 V, 60 Hz A2 – 220 V, 50 Hz BA – 240/480 V, 60 Hz; 220/440 V, 50 Hz BB – 480 V, 40 Hz XF – 347 V, 60 Hz CX – 600 V, 60 Hz; 550 V, 50 Hz CC – 600 V, 60Hz C2 – 600 V, 50 Hz NX – 400 V, 50 Hz MX – 500 V, 50 Hz TX – 277 V, 60 Hz | DX – 120 V, 60 Hz PX – 115 V, 50 Hz FX – 230 V, 50 Hz PF – 115/230 V, 50 Hz SX – 120 V, 60 Hz; 110 V, 50 Hz |
| IV. | Fuse Block Options 0 – No primary or secondary fuse blocks provided | |
| V. | Factory Installed Options N - None | |
| VI. | Packaging M – Bulk pack Blank – Single pack | |

NOMENCLATURE (Cont)

Safety Isolating Transformers

| | | | | | | | | | | |
|------|---|----|---|------|---|----|---|---|---|----|
| 1497 | - | K | - | AAJK | - | 0 | - | N | - | M |
| I | | II | | III | | IV | | V | | VI |

| | | |
|------|---|---|
| I. | Product Type 1497 – Industrial control transformer | |
| II. | VA Rating | |
| | A – 63 VA B – 80 VA C – 130 VA D – 200 VA E – 250 VA | F – 350 VA G – 500 VA H – 750 VA J – 800 VA K – 1000 VA |
| III. | Voltage Rating (First 2 characters = Primary Voltage, Second 2 characters = Secondary Voltages) | |
| | HX – 208 V, 60 Hz AX – 240 V, 60 Hz; 220 V, 50 Hz AA – 240 V, 60 Hz AB – 240/480 V, 60 Hz A2 – 220 V, 50 Hz BA – 240/480 V, 60 Hz; 220/440 V, 50 Hz BB – 480 V, 40 Hz XF – 347 V, 60 Hz CX – 600 V, 60 Hz; 550 V, 50 Hz CC – 600 V, 60Hz C2 – 600 V, 50 Hz NX – 400 V, 50 Hz MX – 500 V, 50 Hz TX – 277 V, 60 Hz | JX – 24 V, 60 Hz KX – 24 V, 50 Hz JK – 24 V, 50/60 Hz |
| IV. | Fuse Block Options 0 – No primary or secondary fuse blocks provided | |
| V. | Factory Installed Options N - None | |
| VI. | Packaging M – Bulk pack Blank – Single pack | |

NOMENCLATURE (Cont)

Multi-Tap Control Transformers

| | | | | | | | | | | |
|------|---|----|---|-----|---|----|---|---|---|----|
| 1497 | - | M | - | M4 | - | 0 | - | N | - | M |
| I | | II | | III | | IV | | V | | VI |

| | | |
|------|---|---|
| I. | Product Type 1497 – Industrial control transformer | |
| II. | VA Rating | |
| | A – 63 VA B – 80 VA C – 130 VA D – 200 VA E – 250 VA F – 350 VA | G – 500 VA H – 750 VA J – 800 VA K – 1000 VA L – 1600 VA M – 2000 VA |
| III. | Voltage Rating M1 – 240, 208 V primary; 120 V secondary, 60 Hz M3 – 240, 208 V primary; 24, 120 V secondary, 60 Hz M4 – 415, 400, 380 V primary; 115, 230 V secondary, 50 Hz | |
| IV. | Fuse Block Options 0 – No primary or secondary fuse blocks provided | |
| V. | Factory Installed Options N - None | |
| VI. | Packaging M – Bulk pack Blank – Single pack | |

Multi-Tap Safety Isolating Transformers

| | | | | | | | | | | |
|------|---|----|---|-----|---|----|---|---|---|----|
| 1497 | - | K | - | M2 | - | 0 | - | N | - | M |
| I | | II | | III | | IV | | V | | VI |

| | | |
|------|---|---|
| I. | Product Type 1497 – Industrial control transformer | |
| II. | VA Rating | |
| | A – 63 VA B – 80 VA C – 130 VA D – 200 VA E – 250 VA | F – 350 VA G – 500 VA H – 750 VA J – 800 VA K – 1000 VA |
| III. | Voltage Rating M2 – 240, 208 V primary; 24 V secondary, 60 Hz M5 – 415, 400, 380 V primary; 24 V secondary, 50 Hz | |
| IV. | Fuse Block Options 0 – No primary or secondary fuse blocks provided | |
| V. | Factory Installed Options N - None | |
| VI. | Packaging M – Bulk pack Blank – Single pack | |