

Certificate of Compliance

Certificate: 2524249

Master Contract: 221418

Project: 2524249

Date Issued: May 29, 2012

Issued to: Rockwell Automation, Inc.
Allen-Bradley
1201 South Second St
Milwaukee, WI 53204
USA

Attention: Ms. Denise L. Denault

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Kim Atkins

Issued by: K. Atkins

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - Certified to US Standards

Relay sockets, open type, for din-rail mounting in industrial control panels, Models 700-HN262 and 700-HN264, rated 12A, 300 Vac.

Notes:

1. Open type devices are Certified as component parts or other equipment where the suitability of the combination is to be determined by CSA International.
2. Relays sockets were tested at ambient temperatures higher than 40 C. See Tests section of report for ambient temperatures and derated current values

Certificate: 2524249

Project: 2524249



Master Contract: 221418

Date Issued: May 29, 2012

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 0-M91(R2001) - General Requirements – Canadian Electrical Code, Part II
CAN/CSA-C22.2 No. 14-05 - Industrial Control Equipment
UL 508 (Edition 17) - Industrial Control Equipment

MARKINGS

Company's identification and/or CSA Master Contract Number 221418, type designation, electrical rating, the wording "75 wire only" and CSA Monogram with indicators C/US is silk-screen printed on the socket.