

EU Declaration of Conformity

<i>Product:</i>	Global Motor Circuit Protectors	
-----------------	--	--

<i>Name and address of the manufacturer:</i>	Rockwell Automation, Inc. 1201 South 2nd Street Milwaukee, WI 53204 USA	<i>Name and address of the authorised representative:</i>	Rockwell Automation B.V. Rivium Promenade 160 2909 LM Capelle aan den IJssel The Netherlands
--	---	---	---

This declaration of conformity is issued under the sole responsibility of the manufacturer.

<i>Object of the declaration:</i>	Allen-Bradley 140MG-G Series (reference the attached list of catalogue numbers)		
-----------------------------------	---	--	--

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2006/95/EC & 2014/35/EU	Low Voltage Directive	(LVD)
2004/108/EC & 2014/30/EU	EMC Directive	(EMC)


References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 60947-2:2006 + A1:2009 + A2:2013	Low-voltage switchgear and controlgear – Part 2: Circuit-breakers
--	---

Additional information:

<i>Year of CE Marking (LVD):</i>	2014
----------------------------------	------

Signed for and on behalf of the above named manufacturer:

<i>Place and date of issue:</i>	Milwaukee, WI USA	19-Jan-2016
<i>Name, function:</i>	Daniel L. Nachtigall – Technical Leader, Product Certification Engineering	
<i>Signature:</i>		

Catalogue number	Series ¹	Description	Directive ²	
			EMC	LVD
140MG-Gxxx-x-x-x		125 A motor circuit protector assembly per Nomenclature	Yes	Yes

- 1) If no series number is given, then all series are covered.
 2) Yes = Product is certified to this directive.

NOMENCLATURE

140MG	-	G	8	P	4	-	C70	-	SD	-	KA
I		II	III	IV	V		VI		VII		VIII

I	Product Type 140MG – Global motor circuit protector
II	Frame/Current Rating G – G frame/125 A
III	Interrupting Rating/Breaking Capacity (Based on I _c at 480V) 8 – High break
IV	Protection Type P – Adjustable magnetic only
V	Number of Poles 3 – 3 poles 4 – 4 poles
VI	Current Rating (* Denotes a two digit number) B* – Current ratings of 3...7 A C* – Current ratings of 15...80 A D* – Current ratings of 100...125 A
VII	Factory-Installed Internal Options Blank – No installed option SJ – Shunt trip; 24...30V AC/DC SK – Shunt trip; 48...60V AC/DC SD – Shunt trip; 110...127V AC, 110...125V DC SA – Shunt trip; 220...240V AC, 220...250V DC SB – Shunt trip; 380...440V AC SC – Shunt trip; 480...525V AC UJ – Undervoltage release; 24...30V AC/DC UR – Undervoltage release; 48V AC/DC UD – Undervoltage release; 110...127V AC, 110...125V DC UA – Undervoltage release; 220...240V AC, 220...250V DC UB – Undervoltage release; 380...440V AC UC – Undervoltage release; 480...525V AC
VIII	Factory-Installed Internal Options Blank – No installed option KA – 1 auxiliary contact, 250V TA – 1 alarm contact, 250V AA – 1 auxiliary contact, 1 alarm contact, 250V BA – 2 auxiliary contacts, 1 alarm contact, 250V AJ – 1 auxiliary contact, 1 alarm contact, 24V