

## *EU Declaration of Conformity*

---

<i>Product:</i>	<b>IEC Miniature Circuit Breakers</b>	
-----------------	---------------------------------------	--

---

<i>Name and address of the manufacturer:</i>	<i>Name and address of the authorised representative:</i>	
<b>Rockwell Automation Inc.</b>	<b>Rockwell Automation B.V.</b>	
<b>1201 South 2nd Street</b>	<b>Rivium Promenade 160</b>	
<b>Milwaukee, WI 53204</b>	<b>2909 LM Capelle aan den IJssel</b>	
<b>U.S.A.</b>	<b>The Netherlands</b>	

---

*This declaration of conformity is issued under the sole responsibility of the manufacturer.*

---

<i>Object of the declaration:</i>	<b>Allen-Bradley 1489-M Series</b>	
	<i>(reference the attached list of catalogue numbers)</i>	

---

*The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:*

2014/35/EU	Low Voltage Directive	(LVD)
2011/65/EU	RoHS Directive	(RoHS)


---

*References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:*

EN 60947-1:2007 + A1:2011 + A2:2014	Low-voltage switchgear and controlgear – Part 1: General rules
EN 60947-2:2006 + A1:2009 + A2:2013	Low-voltage switchgear and controlgear – Part 2: Circuit-breakers
EN 50581:2012	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

---

*Signed for and on behalf of the above named manufacturer:*

<i>Place and date of issue:</i>	Milwaukee, WI USA	27-June-2017
<i>Name, function:</i>	Daniel L. Nachtigall, Technical Leader – Product Certification Engineering	
<i>Signature:</i>		

---

<i>Catalogue number</i>	<i>Series <sup>1</sup></i>	<i>Description</i>
1489-Mxxxx		<i>IEC circuit breakers per Nomenclature</i>
1489-AMST2		<i>Shunt trip, 12...60 V AC/DC</i>
1489-AMST1		<i>Shunt trip, 110...415V AC, 110...250V DC</i>

1) If no series number is given, then all series are covered

NOMENCLATURE

1489	-	M	2	C	400
1		2	3	4	5

1	Designates Product Line 1489 – IEC circuit breakers				
2	Designates Interrupting Rating M – 15 kA				
3	Designates Number of Poles 1 – 1 pole 2 – 2 pole 3 – 3 pole				
4	Designates Trip Code C – Trip Curve C D – Trip Curve D				
5	Designates Current Rating				
	005 – 0.5 A	050 – 5 A	150 – 15 A	350 – 35 A	
	010 – 1 A	060 – 6 A	160 – 16 A	400 – 40 A	
	016 – 1.6 A	070 – 7 A	200 – 20 A	500 – 50 A	
	020 – 2 A	080 – 8 A	250 – 25 A	600 – 60 A	
	030 – 3 A	100 – 10 A	300 – 30 A	630 – 63 A	
	040 – 4 A	130 – 13 A	320 – 32 A		