

EC Declaration of Conformity

The undersigned, representing the manufacturer

Rockwell Automation, Inc.
1201 South 2nd Street
Milwaukee, WI 53204
U.S.A.

*and the authorised representative established within the
Community*

Rockwell Automation BV
Rivium 1e Straat, 23
2909 LE Capelle aan den IJssel
Netherlands

herewith declare that the Products: **IEC Circuit Breakers for Equipment**

*Product identification (brand and
catalogue number/part number):*

Allen-Bradley 1492-GH and 1492-GS Series
(reference the attached list of catalogue numbers)

*are in conformity with the essential requirements of the following EC Directive(s) when installed in accordance with
the installation instructions contained in the product documentation:*

2006/95/EC

Low Voltage Directive

and that the standards and/or technical specifications referenced below have been applied:

EN 60934:2001 + A1:2007


Circuit-breakers for equipment (CBE)

Year of CE Marking (Low Voltage Directive):

1995

Manufacturer:


Authorised Representative in the Community:



Signature

Name: Daniel L. Nachtigall
Position: Supv – Product Certification Engineering

Date: 18-Feb-2011



Signature

Name: Viktor Schiffer
Position: Engineering Manager

Date: 23-Feb-2011

<i>Catalogue number</i>	<i>Series ¹</i>	<i>Description</i>
1492-GHx		<i>Single range timing relay per Nomenclature</i>
1492-GSxx		<i>Fixed range timing relay per Nomenclature</i>

1) If no series number is given, then all series are covered

NOMENCLATURE:

1492	-	GH	160
1		2	3

1	Designates Product Type 1492 – Miniature circuit breaker
2	Designates Relay Type GH – High density, single pole
3	Designates Current Rating
	012 – 1.2 A 030 – 3.0 A 080 – 8.0 A
	002 – 0.2 A 015 – 1.5 A 040 – 4.0 A 100 – 10.0 A
	005 – 0.5 A 020 – 2.0 A 050 – 5.0 A 150 – 15.0 A
	008 – 0.8 A 025 – 2.5 A 070 – 7.0 A 160 – 16.0 A
	010 – 1.0 A

1492	-	GS	3	G	250	H1
1		2	3	4	5	6

1	Designates Product Type 1492 – Miniature circuit breaker
2	Designates Relay Type GS – High density, thermal/magnetic
3	Designates Number of Poles 1 – 1 pole 2 – 2 pole 3 – 3 pole
4	Designates Trip Characteristic G – All devices are so rated
5	Designates Current Rating
	020 – 2.0 A 060 – 6.0 A 150 – 15.0 A
	002 – 0.2 A 025 – 2.5 A 070 – 7.0 A 160 – 16.0 A
	005 – 0.5 A 030 – 3.0 A 080 – 8.0 A 200 – 20.0 A
	008 – 0.8 A 040 – 4.0 A 100 – 10.0 A 250 – 25.0 A
	010 – 1.0 A 050 – 5.0 A 120 – 12.0 A
	015 – 1.5 A
6	Designates Options H1 – N.O. auxiliary contacts H2 – N.C. auxiliary contacts