


## *EU Declaration of Conformity*

---

<i>Product:</i>	<b>IEC Miniature Circuit Breakers</b>	
<i>Name and address of the manufacturer:</i>	<b>Rockwell Automation Inc.</b> <b>1201 South Second Street</b> <b>Milwaukee, WI 53204</b> <b>USA</b>	<i>Name and address of the authorised representative:</i> <b>Rockwell Automation B.V.</b> <b>Rivium Promenade 160</b> <b>2909 LM Capelle aan den IJssel</b> <b>The Netherlands</b>
<i>This declaration of conformity is issued under the sole responsibility of the manufacturer.</i>		
<i>Object of the declaration:</i>	<b>Allen-Bradley 1489-M Series</b> (reference the attached list of catalogue numbers)	
<i>The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:</i>		
<b>2006/95/EC &amp; 2014/35/EU</b>	<b>Low Voltage Directive</b>	<b>(LVD)</b>
<i>References to the relevant harmonised standards used or references to the specifications in relation to which conformity is declared:</i>		
<b>EN 60947-1:2007 + A1:2011</b>	<b>Low-voltage switchgear and controlgear – Part 1: General rules</b>	
<b>EN 60947-2:2006 + A1:2009 + A2:2013</b>	<b>Low-voltage switchgear and controlgear – Part 2: Circuit-breakers</b>	
<i>Additional information:</i>		
<i>Year of CE Marking (LVD):</i>	<b>2014</b>	
<i>Signed for and on behalf of the above named manufacturer:</i>		
<i>Place and date of issue:</i>	<b>Milwaukee, WI, USA</b>	<b>22-Jan-2016</b>
<i>Name, function:</i>	<b>Daniel L. Nachtigall – Technical Leader, Product Certification Engineering</b>	
<i>Signature:</i>		

---

<i>Catalogue number</i>	<i>Series <sup>1</sup></i>	<i>Description</i>
1489-Mxxxx		<i>IEC circuit breakers per Nomenclature</i>
1489-AMST2		<i>Shunt trip, 12...60 V AC/DC</i>
1489-AMST1		<i>Shunt trip, 110...415V AC, 110...250V DC</i>

1) If no series number is given, then all series are covered

NOMENCLATURE

1489	-	M	2	C	400
1		2	3	4	5

1	Designates Product Line 1489 – IEC circuit breakers				
2	Designates Interrupting Rating M – 15 kA				
3	Designates Number of Poles 1 – 1 pole 2 – 2 pole 3 – 3 pole				
4	Designates Trip Code C – Trip Curve C D – Trip Curve D				
5	Designates Current Rating				
	005 – 0.5 A	050 – 5 A	150 – 15 A	350 – 35 A	
	010 – 1 A	060 – 6 A	160 – 16 A	400 – 40 A	
	016 – 1.6 A	070 – 7 A	200 – 20 A	500 – 50 A	
	020 – 2 A	080 – 8 A	250 – 25 A	600 – 60 A	
	030 – 3 A	100 – 10 A	300 – 30 A	630 – 63 A	
	040 – 4 A	130 – 13 A	320 – 32 A		